

#### The 2021 Energy Code: HVAC

#### Presented by

Duane Jonlin, Energy Code and Energy Conservation Advisor | Seattle Department of Construction and Inspections

Ben Roush, Principal | FSi Engineers

March 20, 2025





#### slido

Please download and install the Slido app on all computers you use



## Join at slido.com #3596575

(i) Start presenting to display the joining instructions on this slide.

#### Webinar Procedures

- All attendees are on mute
- Submit questions at any time
- The webinar is being recorded
- Please take the after-class survey!



Look for the Questions icon in the top menu bar



 Chat icon – disabled except for admin



Join at slido.com #3596575 passcode: cnn08n

### What Is This "Lighting Design Lab"?

- Seattle City Light's go-to resource for lighting and lighting controls since 1989 – 30+ years
- Formed by BPA and NW utilities to fill education needs for the transforming market
- Now expanded to include resources that support whole buildings
- Being rebranded!




Join at slido.com #3596575 passcode: cnn08n



#### slido

Please download and install the Slido app on all computers you use





(i) Start presenting to display the poll results on this slide.



Please download and install the Slido app on all computers you use





# Where do you do most of your work?

(i) Start presenting to display the poll results on this slide.

### **Upcoming Events**

|              | Cours | e  | Day          | Time             |
|--------------|-------|--|--------------|------------------|
|              | Don't | Be Burned by Boiler Decarb Retrofits                     | Tue April 1  | 10:00-11:00 a.m. |
| Oper<br>Soon |       | 2021 WA & Seattle Commercial Energy Codes: Water Heating | Thu April 17 | 10:00-11:30 a.m. |
|              | oon!  | 2021 WA & Seattle Commercial Energy Codes: Alterations   | Thu May 15   | 10:00-11:30 a.m. |

| Event                                      | Day        | Time      |
|--|------------|-----------|
| Seattle City Light Trade Ally Office Hours | Fri Mar 21 | 9:00 a.m. |

Stay up-to-date at LightingDesignLab.com and by subscribing to our newsletter.

## The 2021 Energy Code HVAC

Seattle City Light Lighting Design Lab March 2025



**Ben Roush**, Principal, PE-ME, FPE, LEED AP BD+C, ASHRAE BEMP & BEAP, Certified Commissioning Professional, Certified Energy Plans Examiner, Fire Plans Examiner

Mechanical & FP Engineer

Board Chair Emeritus, USGBC-MD

USGBC E&A TAG Vice Chair (yay v5! Go vote)

AIA MD COTE Chair

Sustainable Mechanical Engineering

**Energy Modeling and Auditing** 

150+ LEED Projects

2 Certified Living Buildings

11 current projects targeting Net Zero Code Nerd



#### It's not whether we're going to do this, it's how



Washington state: 70% less building energy use by 2030

- Zero-carbon buildings
- Gov says move faster

Seattle City Light

**Seattle** Department of Construction & Inspections

<u>Washington state</u>: 45% reduction in GHG emissions by 2030

95% reduction by 2050

<u>Seattle</u>: Carbon-neutral building & vehicle operations by 2050

 ...or sooner with Green New Deal?

#### Seattle amendments: 4 Guiding Principles

- 1. Envelopes meet our "2050" standard
  - We have to decide what that 2050 standard is
- No "internal combustion buildings"
  - Electrical infrastructure for exceptions
- 3. Efficient use of electricity
  - Typically heat pumps for space heating & water heating
- 4. Increased on-site renewables
  - Options for off-site purchase

**Seattle** Department of Construction & Inspections

• Plus "solar readiness" for bigger future system

Seattle City Light

Seattle: "Intent" section includes "reduction of carbon emissions"

Today:

**HVAC** 

#### New buildings must be capable of meeting Seattle's 2050 targets.

### What belongs on our HVAC Top 10 list?

- 1. Commissioning
- 2. Metering
- 3. Heating type
- 4. TSPR
- 5. DOAS
- 6. Economizers
- 7. Energy Recovery
- 8. Controls
- 9. DDC

Seattle Department of

Construction & Inspections


#### **10**. C406 options

Seattle City Light



#### + Special Occupancies

- Commercial kitchen
- Data center cooling
- Refrigerated spaces
- Multifamily
- Garage/loading dock
- Outdoor café
- Lab exhaust
- Hotel guest room
- Grocery



#### **Engineering Terms**



Liquid Line Heat Pump 6 4 Expansion Device Performance COP Evaporator (Indoors)  $T_{cond}$ Condenser  $T_{evap}$ (Outdoors) KitchenAid Vapor Line 3 Compressor

Resistance: 1kW in=1kW Work Out **Refrigeration cycle:** 1kW in=3kW Work Out


#### Heat Pump Layout





#### Heat Pump Layout, variable speed











### **Engineering View, Limitations**




Performance of typical 2-ton air-source heat pump

5.60 40,000 COEFFICIENT OF PERFORMANCE (COP) 35,000 4.60 30,000 BTU/HR 25,000 3.60 20,000 2.60 15,000 10,000 1.60 5,000 **CANNOT MEET** CAN MEET **HEATING REQUIREMENT HEATING REQUIREMENT** 0. 0.60 -10 0 10 20 30 40 50 60 70 **OUTDOOR AIR TEMP (°F)** Spokane **Seattle** 

Heat PumpPerformance,Cold Temp Impacts(cheap version)


### **Engineering View, Less Limitations**

#### Variable Speed Version



The Effects of Outside Temperature and


Daikin VRV Standard Series REYQ192TYDN 16 Ton HR COP Curves



OUTDOOR AIR TEMP WB (°F)


#### **Engineering View, Cost**





#### Sea <u>& WA</u>: Envelope U-value of PTAC/PTHP C402.1.3


- Conventional PTAC & PTHP units leak heat & leak air badly
- Through-wall mech units assigned default value of **U-0.500** 
  - Unless mfr has tested U-value
  - (wood framed wall is U-0.051)








### Fenestration U-factors



### High-Performance U-Factors



#### WA & Seattle Air Barrier Testing

Q: Do your HVAC design calcs still assum 1.0 cfm leakage?

- Test standard <u>0.25</u> cfm/sf of envelope
- Passing test now <u>mandatory</u>
  - ...at <u>0.25</u> cfm/sf

 …and Seattle U-factors are close to Minnesota's



### How is HVAC section organized? (It's not)

#### C403.1.1 TSPR

C403.1.2 Load calculations C403.1.3 Data centers C403.1.4 Fossil fuel and electric resistance

C403.2 System design. (zone isolation, ventilation & exhaust, variable speed drives)

**C403.3 Equipment selection & Tables** (sizing, performance, chillers, humidification)


C403.3.5 DOAS (occupancy table, energy recovery, decoupled supply air) C403.3.7 Hydronic flow rate C403.4 HVAC system controls (thermostats, heat pump supplementary heat, deadband, vestibules, door switch)

#### C403.4.3 Hydronic system controls

(hydronic heat pump controls, dead band, heat rejection, isolation valves, part load controls, pump isolation, variable flow controls)
C403.4.9 Multifamily units
C403.5 Economizers
C403.6 Multi-zone systems
C403.6.10 High-efficiency VAV systems (alternative to DOAS)
C403.7 Ventilation and exhaust (DCV,

**C403.7 Ventilation and exhaust** (DCV, occ sensor, loading dock, garage) **C403.7.6 Energy recovery ventilation C403.7.6.1 Balanced ventilation** for R-2 C403.7.7 Exhaust systems (kitchen, laboratory) C403.7.8 Shutoff dampers C403.8 Fans and fan controls C403.9 Heat rejection & heat recovery C403.10 HVAC system construction (ducts, pipes, insulation, sealing) C403.11 Systems outside thermal envelope (radiant heaters, snow melt, freeze protection) C403.12 High-efficiency single-zone **VAV** (alternative to DOAS) C403.13 Dehumidification in grow op C403. 14 Commissioning C403.15 Clean water pumps

### Flow Chart Moment!



### **Mechanical Changes**



#### Table C403.4.11.1

## Largely unchanged mech efficiencies

Mechanical Controls

**DOAS Clarifications** 

Total System Performance Ratio


C407 changes

| DDC Applications and Qualifications |  |  |  |  |
|-------------------------------------|--|--|--|--|
| Building<br>Status                  | Application  | Qualifications   |  |  |
| New                                 |  |  |  |  |
| building                            | Air-handling system and all zones served by the system                       | Individual systems supplying more than three zones and with fan system bhp of 10 hp and larger   |  |  |
|                                     | Chilled-water plant and all coils and<br>terminal units served by the system | Individual plants supplying more than three zones and with design cooling capacity of 300,000 Btu/h and larger                                 |  |  |
|                                     | Hot-water plant and all coils and terminal units served by the system        | Individual plants supplying more than three zones and with design heating capacity of 300,000 Btu/h and larger                                 |  |  |
| Alteration<br>or addition           | Zone terminal unit such as VAV box   | Where existing zones served by the same air-handling, chilled-<br>water, or hot-water system have DDC  |  |  |
|                                     | Air-handling system or fan coil  | Where existing air-handling system(s) and fan coil(s) served by<br>the same chilled- or hot-water plant have DDC                               |  |  |
|                                     | New air-handling system and all new zones served by the system               | Individual systems with fan system bhp of 10 hp and larger and<br>supplying more than three zones and more than 75 percent of<br>zones are new |  |  |
|                                     | New or upgraded chilled-water plant  | Where all chillers are new and plant design cooling capacity is 300,000 Btu/h and larger   |  |  |
|                                     | New or upgraded hot-water plant  | Where all boilers are new and plant design heating capacity is 300,000 Btu/h and larger  |  |  |

#### DDC Applications and Qualifications

### Data Center Cooling Efficiency C403.1.3

- WA & Seattle: ASHRAE 90.4 – 2022, no modifications
- 90.4, Section 6 & 8









#### Sections 6 and 8

**DATA CENTER.** A room or series of rooms that share *Data Center Systems* whose primary function is to house equipment for the processing and storage of electronic data, which has a design total *information technology equipment (ITE)* equipment power density exceeding 20 watts per square foot of conditioned area and a total design ITE equipment load greater than 10 kW.

**COMPUTER ROOM.** A room whose primary function is to house equipment for the processing and storage of electronic data and that has a design total *information technology equipment (ITE)* equipment less than or equal to 20 watts per square foot of conditioned area or a design *ITE* equipment load less than or equal to 10 kW.





Proudly Operated by Battelle Since 1965

# TSPR = Heating + Cooling Loads(annual)Carbon Emissions



TSPR: Total System Performance Ratio Office, Medical office, Retail, Library, Education, Multifamily


TSPR evaluates HVAC efficiency by comparing:
required annual heating & cooling, to
carbon emissions due to heating & cooling
Free online calculation tool from PNNL

### Clarifying TSPR table – what's in, what's out

#### Table C403.1.1 – Occupancy Classifications Requiring TSPR

| Occupancy<br>Classification | Inclusions  | Excluded  |
|-----------------------------|---|---|
| Α                           | Library   | All other Group A uses  |
| В                           | Office, medical office  | All other Group B uses  |
| E                           | All occupancies included  |   |
| Μ                           | All occupancies included  |   |
| R                           | Dwelling units and common<br>areas within Group R-2 areas<br>of buildings | Groups R-1 and R-3 occupancies.<br>Sleeping units and associated<br>residential common areas in Group R-2 |
| F, H, I, S, U               |   | All occupancies   |

### TSPR, outcomes from the real world




fsi

#### Engineering View, Future CO2



CO2 OVER TIME




#### DOAS scope (C403.3.5)

- Office, education, retail, library, assembly
- "Accessory Occupancies" exempt
- Seattle: DOAS fan power 0.8 W/cfm
- DOAS can "temper" air up to 55, or cool for dehumidification (C403.7.3)

Seattle City Light

**Seattle** Department of Construction & Inspections



Dedicated Outdoor Air System: Ventilation is "decoupled" from heating & cooling, has energy recovery

#### Clarifying DOAS table – what's in, what's out Table C403.3.5 – Occupancy Classifications Requiring DOAS

| Occupancy<br>Classification | Inclusions               | Exempted  |
|-----------------------------|--------------------------|---|
| A-1                         | All not exempted         | TV & radio studios  |
| A-2                         | Casino gaming areas      | All other A-2 uses (dining/drinking)  |
| A-3                         | Lecture halls            | All other A-3 uses  |
| A-4 & A-5                   |                          | All occupancies   |
| B                           | All not exempted         | Commercial kitchens, restaurants, labs,<br>data centers, animal hospitals, kennels,<br>pounds, ambulatory care facilities |
| E, M                        | All occupancies included |   |
| F, H, I, R, S, U            |                          | All occupancies   |



#### **Special Assembly Occupancies**

fsi

Large Concert Halls

Small Lecture Rooms

Gymnasiums

Places of Religious Worship



### DCV Required C403.7.1.1

- Single-zone systems with economizer
- Spaces <del>over 500 sf</del> with 15 occ's per 1000 sf need DCV
  - So, includes retail sales floors

**Seattle** Department of Construction & Inspections

- Exempts several small occupancy types
- Exception for dining rooms that use most of their outdoor air for adjacent kitchen makeup air
- Exception for "total system design outdoor airflow" less than 750 cfm (or 1500 cfm with 60% effective ERV)

Seattle City Light

 Exception for multi-zone system with "design occupant component outdoor airflow" less than 100 cfm (or 200 cfm with 60% effective ERV)



### DOAS & Economizers C403.3.5

- Economizer *required* for DOAS if cooling equipment is outdoors or in a space adjacent to an exterior wall or roof.
  - Exception 1b only applies if chiller is buried in some interior space


**C403.5 Economizers.** *Air economizers* shall be provided on all new cooling systems including those serving computer server rooms, electronic equipment, radio equipment, and telephone switchgear. Economizers shall comply with Sections C403.5.1 through C403.5.5.

More Exceptions...






#### A. Basic arrangement of a conventional all-air VAV system



#### DOAS, demystified




B. DOAS with separate conditioning of outdoor and return air






B. DOAS with separate conditioning of outdoor and return air




### DOAS, ERV, and economizer






### **Effectiveness and Efficiency**



fsi

### Effectiveness (Energy)





# "Balanced ventilation" R-2 dwelling units C403.7.6.1

#### R-2 dwelling & sleeping units

- Deliver ventilation air directly to each "habitable space"
  - Living room, bedrooms
  - Trickle vents & bathroom exhaust doesn't work anymore
- Heat recovery required
  - w/ 67% sensible heat recovery effectiveness (60% in WA code)
  - "Informative note" about how to determine sensible heat recovery effectiveness from HVI publication


#### Individual HRVs in apts?

- Remember you still need to clean every filter twice a year
- Rooftop units?
  - Shafts eat up rentable floor area
- Floor-by-floor HRVs?
  - Each serving 6 8 units
  - Ducts running above bathrooms
    - Noise/privacy problem?


#### "Fossil Fuel Compliance Path" to resolve recent federal court ruling – C401.3

Gas heating & water heating OK, *if* total building efficiency is same as heat pump building:

Just add enough efficiency credits to make up the difference



### Turns out it takes a *lot* of credits



Because: Heating/water heating are huge share of total energy use, and gas boilers consume triple the energy of heat pumps



# Seattle <u>& WA</u>: Heat pump space heating ...or use "fossil fuel compliance path"

# No electric resistance or fossil fuel combustion for space heating

**Exceptions** allow <u>electric resistance heat</u> for:


- 1. <u>"Passive House"rule</u>: Max 2.5 W/sf total installed heating
- 2. <u>Dwelling & sleeping units</u>: Max <u>750 W</u> per habitable room

Seattle City Light

- 1000 W for corner room
- 250 W for room at exterior wall, but no window
- 3. Buildings smaller than 2,500 sf
- 4. Heat pump <u>defrost</u>

**eattle** Department o

Construction & Inspections



#### Heat pumps squeeze warmth out of cold air

# C403.1.4 (space heating) More Exceptions

- 5. Air-to-air heat pumps
  - Compressor is first stage of heat down to 17°F, capacity is 2X elec resistance
- 6. Air-to-water heat pump
  - 1. All sizes
  - 2. Auxiliary heat locked out down to 36°F
    - 1. Fossil fuel auxiliary OK in CZ 5 only
  - 3. Compressor is first stage of heat down to lowest design temp
  - 4. Capacity at 17°F is min 75% of cap at 29°F
- 7. Ground-source HP
- 8. Small systems
- 9. Specific conditions (if *approved*)
- 10. Kitchen make-up air

- 11. District energy
- 12. Heat tape
- 13. Temporary systems
- 14. Pasteurization cycle
- 15. Freeze protection
- 16. DOAS ERV auxiliary heat
- 17. Low-carbon district energy
- 18. Essential facilities
- 19. Standby heating equipment
- 20. Emergency generators
- 21. Wastewater heat recovery pumps
- 22. Heating outside envelope.

48



#### No electric resistance or gas heat (?)





Airside systems we can use

#### No electric resistance or gas heat (?)







Waterside systems we can use

# Simultaneous heating/cooling C403.4.1

- In "thermostatic control" section
- You can't have heating in the perimeter zone with cooling in the interior zone of the same space at the same time.
  - Duh-oh!
  - You *can* have one zone in heating or cooling while the other is neutral


Seattle City Light

 Permanent opening between areas bigger than 10% of either floor area constitute a single space for this requirement



#### **Simultaneous Heating and Cooling**





# C403.7, Ventilation and Exhaust Systems

fsi

- DCV (already mentioned)
- Occupancy Sensors
- Ventilation heating control
- Garage Ventilation
- Energy Recovery Ventilation
- Kitchen Hoods
- Labs
- Building Isolation Dampers



#### Kitchen ventilation & exhaust



#### TABLE C403.7.7.1.2 MAXIMUM NET EXHAUST FLOW RATE, CFM PER LINEAR FOOT OF HOOD LENGTH


| TYPE OF HOOD             | LIGHT-DUTY<br>EQUIPMENT | MEDIUM-DUTY<br>EQUIPMENT | HEAVY-DUTY<br>EQUIPMENT | EXTRA-HEAVY-<br>DUTY EQUIPMENT |
|--------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|
| Wall-mounted canopy      | 140                     | 210                      | 280                     | 385                            |
| Single island            | 280                     | 350                      | 420                     | 490                            |
| Double island (per side) | 175                     | 210                      | 280                     | 385                            |
| Eyebrow                  | 175                     | 175                      | NA                      | NA                             |
| Backshelf/Pass-over      | 210                     | 210                      | 280                     | NA                             |

For SI: 1 cfm = 0.4719 L/s; 1 foot = 305 mm. NA = Not Allowed

### Heat Recovery C403.9.2

- **Condenser heat recovery required** to heat service hot water in buildings (like hospitals) with:
  - 24/7 operations
  - Min 1.5 MBTUH total heat rejection of water-cooled systems
  - Min 250 kBTUH service water heating load
- Steam condensate water recovery required
  - Or condensate *heat recovery* for off-site steam with no return
- Refrigeration condenser heat recovery (like groceries)
  - 500 kBTUH remote refrigeration condensers
  - Use heat for service water, space heating, or dehumidification





### Heat recovery for space heating C403.9.2.1

- Heat recovery from 90% of exhaust airflow
  - Leaving exhaust air temp max 55F in full heat recovery mode
- Process heat recovery (like data center or computer room) over 5 W/ft<sup>2</sup>
  - Cooling loops must be served by water-cooled equip & heat recovery
  - Economizer override required
- 90% of heating from heat recovery chiller or water-to-water heat pump, rejecting heat from cooling loop to heating loop as first stage of heating
- Water-source **condenser heat** recovery system required if:
  - Operating hours over 70 hours per week
  - Heat rejection equip capacity over 1.5 MBTUH
  - Min 0.45 cfm/sf airflow in zones with reheat
  - EXCEPTION: DOAS dedicated outdoor air systems

#### Heat Recovery Engineering Notes



## Break Time!



Seattle Department of Construction & Inspections



#### C406 Efficiency credits system Pick a few "above-code" measures from 31 options

#### Table C406.1 Energy Measure Credit Requirements

| <b>Required Credits for</b>                                   |         | Occupancy Group |           |         |         |         |           |  |  |
|---|---------|-----------------|-----------|---------|---------|---------|-----------|--|--|
| Projects  | Section | Group R-1       | Group R-2 | Group B | Group E | Group M | All Other |  |  |
| New building<br>energy efficiency<br>credit requirement       | C406.2  | 54              | 41        | 42      | 48      | 74      | 49        |  |  |
| Building additions<br>energy efficiency<br>credit requirement | C406.2  | 27              | 20        | 21      | 23      | 36      | 21        |  |  |
| New building load<br>management credit<br>requirement         | C406.3  | 12              | 15        | 27      | 15      | 13      | 26        |  |  |

Plus "load management credits"

| Table   |   |                       | Occupancy Group                        |  |   |   |  |   |  |
|---|---|-----------------------|--|--|---|---|--|---|--|
| C406.2  | Measure Title   | Applicable<br>Section | Group R-<br>1                          | Group<br>R-2                           | Group<br>B                              | Group<br>E                              | Group M                                | All<br>Other                            |  |
|   | 1. Dwelling unit<br>HVAC control  | C406.2.1              | NA                                     | 7                                      | NA                                      | NA                                      | NA                                     | NA                                      |  |
| List all your<br>HVAC-related<br>efficiency credits<br>& load mgmt. | 2. Improved HVAC<br>TSPR <sup>a</sup>   | C406.2.2.1            | NA                                     | 8                                      | 11                                      | 17                                      | 22                                     | NA                                      |  |
|   | 3. Improve cooling<br>and fan efficiency  | C406.2.2.2            | <mark>((<del>2</del>)) <u>8</u></mark> | <mark>((<del>2</del>)) <u>5</u></mark> | <mark>((<del>3</del>)) <u>10</u></mark> | <u>((4)) 10</u>                         | <mark>((<del>3</del>)) <u>8</u></mark> | <mark>((<del>2</del>)) <u>8</u></mark>  |  |
|   | 4. Improve heating efficiency   | C406.2.2.3            | <mark>((2)) <u>1</u></mark>            | <mark>((<del>3</del>)) <u>1</u></mark> | <mark>((<del>3</del>)) <u>1</u></mark>  | <mark>((<del>10</del>)) <u>1</u></mark> | <mark>(16)) <u>2</u></mark>            | <mark>((7)) <u>1</u></mark>             |  |
| credits on HVAC<br>set cover page                                   | 5. Improved low-<br>carbon district<br>energy system (10%<br>better)              | C406.2.2.4            | 3                                      | 3                                      | 4                                       | 11                                      | 17                                     | 8                                       |  |
|   | 6. Improved low-<br>carbon district<br>energy system (20%<br>better) <sup>b</sup> | C406.2.2.5            | 9                                      | 10                                     | 12                                      | 33                                      | 52                                     | 24                                      |  |
|   | 7. High performance<br>DOAS   | C406.2.2.6            | 31                                     | 31                                     | 21                                      | 39                                      | 40                                     | 21/<br>( <u>Group</u><br><u>A:</u> 40)° |  |
|   | 8. Fault detection & diagnostics (FDD)  | C406.2.2.7            | 2                                      | 2                                      | 2                                       | 6                                       | 9                                      | 4                                       |  |

# C406 credit example: Improved TSPR C406.2.2.1

- TSPR 5% above code
- Or prorated up to 20% higher TSPR

Seattle City Light





#### Load management credits Table C406.3

|                                     |                       | Occupancy Group |              |            |            |            |              |  |  |
|-------------------------------------|-----------------------|-----------------|--------------|------------|------------|------------|--------------|--|--|
| Measure Title                       | Applicable<br>Section | Group R-1       | Group<br>R-2 | Group<br>B | Group<br>E | Group<br>M | All<br>Other |  |  |
| 1. Lighting load management         | C406.3.1              | 12              | 15           | 27         | 15         | NA         | NA           |  |  |
| 2. HVAC load management             | C406.3.2              | 29              | 24           | 42         | 23         | 13         | 26           |  |  |
| 3. Automated shading                | C406.3.3              | NA              | 7            | 12         | 16         | NA         | NA           |  |  |
| 4. Electric energy storage          | C406.3.4              | 41              | 50           | 126        | 72         | 37         | 65           |  |  |
| 5. Cooling energy storage           | C406.3.5              | 13              | 10           | 14         | 19         | NA         | 14           |  |  |
| 6. Service hot water energy storage | C406.3.6              | 31              | 248          | 59         | 8          | 5          | 70           |  |  |
| 7. Building thermal mass            | C406.3.7              | NA              | NA           | 50         | 95         | 96         | 80           |  |  |



#### C406 TSPR Credit: Engineering Notes

#### TABLE C406.2 EFFICIENCY MEASURE CREDITS

| EFFICIENCY MEASURE CREDITS |  |            |              |                 |            |            |                  |                            |  |
|----------------------------|--|------------|--------------|-----------------|------------|------------|------------------|----------------------------|--|
|                            |  | Applicable |              | Occupancy Group |            |            |                  |                            |  |
|                            | Measure Title  | Section    | Group<br>R-1 | Group<br>R-2    | Group<br>B | Group<br>E | Group M          | All Other                  |  |
| 1.                         | Dwelling unit HVAC control   | C406.2.1   | NA           | 7               | NA         | NA         | NA               | NA                         |  |
| 2.                         | Improved HVAC TSPR <sup>a</sup>  | C406.2.2.1 | NA           | 8               | 11         | 17         | 22               | NA                         |  |
| 3.                         | Improve cooling and fan<br>efficiency                                      | C406.2.2.2 | 2            | 2               | 3          | 4          | 3                | 2                          |  |
| 4.                         | Improve heating efficiency   | C406.2.2.3 | 2            | 3               | 3          | 10         | 16               | 7                          |  |
| 5.                         | Improved low-carbon<br>district energy system<br>(10% better)              | C406.2.2.4 | 3            | 3               | 4          | 11         | 17               | 8                          |  |
| 6.                         | Improved low-carbon<br>district energy system<br>(20% better) <sup>b</sup> | C406.2.2.5 | 9            | 10              | 12         | 33         | 52               | 24                         |  |
| 7.                         | High performance DOAS  | C406.2.2.6 | 31           | 31              | 21         | 39         | 40               | 21/<br>(A) 40 <sup>c</sup> |  |
| 8.                         | Fault detection &<br>diagnostics (FDD)                                     | C406.2.2.7 | 2            | 2               | 2          | 6          | 9                | 4                          |  |
| 9.                         | 10% reduced lighting<br>power  | C406.2.3.1 | 7            | 4               | 18         | 16         | 20               | 15                         |  |
| 10.                        | 20% reduced lighting<br>power <sup>d</sup>                                 | C406.2.3.2 | 13           | 8               | 36         | 32         | 40               | 29                         |  |
| 11.                        | Lamp efficacy<br>improvement   | C406.2.3.3 | 5            | 6               | NA         | NA         | NA               | NA                         |  |
| 12.                        | Residential lighting control   | C406.2.4.1 | NA           | 8               | NA         | NA         | NA               | NA                         |  |
| 13.                        | Enhanced lighting control  | C406.2.4.2 | 1            | 1               | 6          | 6          | 11               | 6                          |  |
| 14.                        | Renewable energy   | C406.2.5   | 7            | 12              | 13         | 13         | 10               | 11                         |  |
| 15.                        | Shower drain heat<br>recovery  | C406.2.6.1 | 9            | 30              | NA         | 3          | NA               | NA                         |  |
| 16.                        | Service water heat<br>recovery   | C406.2.6.2 | 35           | 111             | 13         | 14         | (Grocery)<br>41° | NA                         |  |
| 17.                        | Heat pump water heating  | C406.2.6.3 | 81           | 261             | 17         | 33         | (Grocery)<br>95° | (A-2)<br>95 <sup>f</sup>   |  |
| 18.                        | Heat trace system  | C406.2.7.1 | 6            | 13              | 4          | 1          | NA               | 6                          |  |
| 19.                        | Point of use water heater  | C406.2.7.2 | NA           | NA              | 19         | 5          | NA               | NA                         |  |
|                            |  |            |              |                 |            |            |                  |                            |  |

#### TABLE C406.2 - Continued EFFICIENCY MEASURE CREDITS

| Occupancy Group   |                       |                 |                 |                 | р               |                 |                 |
|---|-----------------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| Measure Title   | Applicable<br>Section | Group<br>R-1    | Group<br>R-2    | Group<br>B      | Group<br>E      | Group M         | All Other       |
| <ol> <li>Service hot water<br/>distribution right sizing</li> </ol>         | C406.2.8              | 13              | 42              | NA              | NA              | NA              | NA              |
| 21. High performance service<br>hot water temperature<br>maintenance system | C406.2.9              | 6               | 13              | 4               | 1               | NA              | 6               |
| 22. High efficiency service hot<br>water circulation system                 | C406.2.10             | 3               | 6               | 2               | 1               | NA              | 4               |
| <ol> <li>Low flow residential<br/>showerheads</li> </ol>                    | C406.2.11             | 3               | 3               | NA              | NA              | NA              | NA              |
| <ol> <li>Enhanced envelope<br/>performance<sup>g</sup></li> </ol>           | C406.2.12             | 24              | 20              | 13              | 5               | 19              | 14              |
| 25. Base reduced air leakage <sup>g</sup>                                   | C406.2.13.2           | 29              | 24              | 6               | 3               | 9               | 11              |
| <ol> <li>Enhanced reduced air<br/>leakage<sup>g</sup></li> </ol>            | C406.2.13.3           | 53              | 44              | 11              | 5               | 16              | 20              |
| <ol> <li>Enhanced commercial<br/>kitchen equipment</li> </ol>               | C406.2.14             | 30 <sup>h</sup> | 18 <sup>h</sup> | 18 <sup>h</sup> | 30 <sup>h</sup> | 30 <sup>h</sup> | 31 <sup>h</sup> |
| <ol> <li>Enhanced residential<br/>kitchen equipment</li> </ol>              | C406.2.15             | 12              | 19              | NA              | NA              | NA              | NA              |
| <ol> <li>Enhanced residential<br/>laundry equipment</li> </ol>              | C406.2.16             | NA              | 6               | NA              | NA              | NA              | NA              |
| 30. Heat pump clothes dryers  | C406.2.17             | 6               | 6               | NA              | NA              | NA              | NA              |
| <ol> <li>Efficient elevator<br/>equipment</li> </ol>                        | C406.2.18             | 3               | 5               | 5               | 5               | 4               | 4               |

a. Projects using Item 2 shall not use Items 3 through 5.

b. Projects using C406.2.2.5 shall not use C406.2.2.4.

- c. For C406.2.2.6, occupancy Group A achieves 40 credits while other occupancy groups within the "all other" category achieve 21 credits.
- d. Projects using C406.2.3.2 shall not use C406.2.3.1.
- e. Service water heat recovery and heat pump water heating are available in Group M only for grocery stores larger than 10,000 ft<sup>2</sup>. Large mixed retail with full grocery and butcher sections shall achieve half the credits. This credit is not available where refrigeration recovery to heat service hot water is used to meet the requirements of Section C403.9.2.3.
- f. Heat pump water heating efficiency credits are available in the "all other" category only for Group A-2.
- g. Buildings or building areas that are exempt from the thermal envelope requirements in accordance with Sections C402.1.1 and C402.1.2, do not qualify for this package.
- Additional energy efficiency credits, up to the maximum shown in Table C406.2, shall be calculated according to Section C406.2.11.



#### HVAC C406 credit for tenant spaces C406.1.1.2


- Where shell & core permit includes C406.2 (HVAC) credit, tenant spaces also qualify if they connect to building HVAC system.
- Tenant space can also qualify for HVAC credit independently

**C406.1.1.2 Applicable HVAC and service water heating credits**. Where HVAC and service water heating systems and services are installed ...**Tenant spaces qualify for the credits assigned to the occupancy type of the tenant space in accordance with Table C406.2 if the tenant space includes the distribution system and equipment that the central HVAC systems or service water heating systems were designed to support.** 

• Seattle: Initial TI permit can use S&C permit code edition within 18 months of C/O

### C406 Engineering Notes





#### Seattle: No C406 credits for fossil fuel equipment

- C406.2.2.6 High-performance dedicated outdoor air system (DOAS). No less than 90 percent of the total conditioned floor area of the whole project, excluding floor area of unoccupied spaces that do not require ventilation as specified by the International Mechanical Code, shall be served by DOAS installed in accordance with Section C403.3.5 with the following adjustments:
- ... No HVAC systems incorporating fossil fuel-fired equipment, or heat from district energy systems that are primarily heated by fossil fuel combustion, are permitted to utilize this credit.
- Same for C406.2.6 Service water heating

۲

...

# Total Building Performance C407

- Use ASHRAE 90.1 Appendix G "Performance Rating Method"
- But using "site energy use," not energy cost
- And use Seattle "mandatory measures" list
  - Can't be "traded" away through modeling
- 10% more stringent than WA code for:
  - Multifamily
  - Hotel
- Use DOE compliance forms
- Energy modeler certification/experience



# Two flavors of site energy

#### Regulated site energy target

- Doesn't count renewables
- Or unregulated loads
   <u>Site energy perf target</u>
- Subtract renewables
- Add unregulated loads:
  - Assumed plug loads
  - And process loads
- Credit for optimizing window area & orientation, equipment efficiency & right-sizing, thermal mass


Table C407.3(2) Building Performance Factors (excluding solar & upregulated)

| (excluding solar & unregulated) |                                   |  |  |  |  |  |
|---------------------------------|-----------------------------------|--|--|--|--|--|
| Building Area Type              | Building Perf<br>Factor (BPF)     |  |  |  |  |  |
| Multifamily                     | (( <del>0.51</del> )) <u>0.45</u> |  |  |  |  |  |
| Health care/hospital            | 0.71                              |  |  |  |  |  |
| Hotel/motel                     | (( <del>0.51</del> )) <u>0.46</u> |  |  |  |  |  |
| Office                          | 0.44                              |  |  |  |  |  |
| Restaurant                      | 0.35                              |  |  |  |  |  |
| Retail                          | 0.41                              |  |  |  |  |  |
| School                          | 0.35                              |  |  |  |  |  |
| Warehouse                       | 0.18                              |  |  |  |  |  |
| All others                      | 0.43                              |  |  |  |  |  |

#### Table C407.3(3) Site Energy Performance Targets (subtract solar, add unregulated)

| •                    | • •                               |
|----------------------|-----------------------------------|
| Building Area Type   | Site Energy Perf<br>Target        |
| Multifamily          | (( <del>0.59</del> )) <u>0.53</u> |
| Health care/hospital | 0.72                              |
| Hotel/motel          | (( <del>0.62</del> )) <u>0.56</u> |
| Office               | 0.58                              |
| Restaurant           | 0.59                              |
| Retail               | 0.46                              |
| School               | 0.52                              |
| Warehouse            | 0.29                              |
| All others           | 0.55                              |








- Compliance with Section C407 requires meeting both a regulated site energy target and a total site energy reduction target in accordance with the following:
  - 1. Regulated site energy target. The regulated site energy target is focused on regulated load energy efficiency, thus shall be met only via regulated load savings without consideration of the contribution of on-site or off-site renewable energy or unregulated load savings. Adjustments to the PCI, to account for the contribution of renewable energy found in ANSI/ASHRAE/IESNA 90.1 Section 4.2.1.1 shall not be used. References to energy cost in Section 4.2.1.1 and Appendix G shall be replaced by site energy use. Heating or cooling energy provided by a district energy system may utilize coefficient of performance (COP) ratios acceptable to the *code official* for the respective district energy sources. The building performance factors in Table 4.2.1.1 of ANSI/ASHRAE/IESNA 90.1 shall be replaced with those in Table C407.3(2).
  - 2.2 Total site energy target. The total site energy performance target shall be met including the contributions of on-site or off-site renewable energy as described in Section C411.2 as well as the contributions of improvements in unregulated loads as allowed by Section C407.3.4. The annual on-site and off-site renewable energy production (as adjusted by the factors in Table C411.2.1) shall be subtracted from the proposed building annual site energy use. Compliance with the site energy performance target requires that the proposed building site energy use/baseline building site energy use is less than or equal to the site energy performance target from Table C407.3(3).

fsi

How hard is this?





- 1A: Miami, Florida (very hot, humid)
- 1B: Riyadh, Saudi Arabia (very hot, dry)
- 2A: Houston, Texas (hot, humid)
- 2B: Phoenix, Arizona (hot, dry)
- 3A: Memphis, Tennessee (warm, humid)
- 3B: El Paso, Texas (warm, dry)
- 3C: San Francisco, California (warm, marine)
- 4A: Baltimore, Maryland (mixed, humid)
- 4B: Albuquerque, New Mexico (mixed, dry)
- 4C: Salem, Oregon (mixed, marine)
- 5A: Chicago, Illinois (cool, humid)
- 5B: Boise, Idaho (cool, dry)
- 5C: Vancouver, B.C. Canada (cool, marine)
- 6A: Burlington, Vermont (cold, humid)
- 6B: Helena, Montana (cold, dry)
- 7: Duluth, Minnesota (very cold)
- 8: Fairbanks, Alaska (subarctic)

### C407, Welcome to ASHRAE 90.1





#### Table 2.4 Building Performance Factors (BPF) for Compliance with Standard 90.1-2016

| Building   | 0A & | 0A & |      |      |      |      |      | Clir | nate Zo | ne   |      |      |      |      |      |      |      | Building<br>Type<br>Average |
|------------|------|------|------|------|------|------|------|------|---------|------|------|------|------|------|------|------|------|-----------------------------|
| Туре       | 1A   | 1B   | 2A   | 2B   | 3A   | 3B   | 3C   | 4A   | 4B      | 4C   | 5A   | 5B   | 5C   | 6A   | 6B   | 7    | 8    | -                           |
| Office     | 0.58 | 0.62 | 0.57 | 0.62 | 0.60 | 0.64 | 0.54 | 0.58 | 0.60    | 0.58 | 0.60 | 0.61 | 0.58 | 0.61 | 0.61 | 0.57 | 0.61 | 0.60                        |
| Retail     | 0.52 | 0.58 | 0.53 | 0.58 | 0.54 | 0.62 | 0.60 | 0.55 | 0.60    | 0.60 | 0.55 | 0.59 | 0.61 | 0.55 | 0.58 | 0.53 | 0.53 | 0.57                        |
| School     | 0.46 | 0.53 | 0.47 | 0.53 | 0.49 | 0.52 | 0.50 | 0.49 | 0.50    | 0.49 | 0.50 | 0.50 | 0.50 | 0.49 | 0.50 | 0.47 | 0.51 | 0.50                        |
| Healthcare | 0.64 | 0.56 | 0.60 | 0.56 | 0.60 | 0.56 | 0.54 | 0.57 | 0.53    | 0.55 | 0.59 | 0.52 | 0.55 | 0.57 | 0.52 | 0.56 | 0.56 | 0.56                        |
| Restaurant | 0.62 | 0.62 | 0.58 | 0.61 | 0.60 | 0.60 | 0.61 | 0.58 | 0.55    | 0.60 | 0.62 | 0.58 | 0.60 | 0.63 | 0.60 | 0.65 | 0.68 | 0.61                        |
| Hotel      | 0.64 | 0.65 | 0.62 | 0.60 | 0.63 | 0.65 | 0.64 | 0.62 | 0.64    | 0.62 | 0.60 | 0.61 | 0.60 | 0.59 | 0.61 | 0.57 | 0.58 | 0.62                        |
| Warehouse  | 0.51 | 0.52 | 0.56 | 0.58 | 0.57 | 0.59 | 0.63 | 0.58 | 0.60    | 0.63 | 0.60 | 0.61 | 0.65 | 0.66 | 0.66 | 0.67 | 0.67 | 0.61                        |
| Apartment  | 0.73 | 0.73 | 0.71 | 0.69 | 0.74 | 0.73 | 0.68 | 0.78 | 0.81    | 0.81 | 0.76 | 0.80 | 0.81 | 0.76 | 0.79 | 0.74 | 0.80 | 0.76                        |
| All Others | 0.62 | 0.61 | 0.55 | 0.57 | 0.56 | 0.61 | 0.59 | 0.58 | 0.57    | 0.61 | 0.57 | 0.57 | 0.61 | 0.56 | 0.56 | 0.53 | 0.52 | 0.58                        |
|            |      |      |      |      |      |      |      |      |         |      |      |      |      |      |      |      |      |                             |

Developing Performance Cost Index Targets for ASHRAE Standard 90.1 Appendix G – Performance Rating Method

March 2016

M Rosenberg R Hart

ENERGY Prepared for the U.S. Department of Energy under Contract DE-AC05-76RL01830

https://www.pnnl.gov/main/pu blications/external/technical\_re ports/PNNL-25202Rev1.pdf

### C407, Welcome to ASHRAE 90.1

#### Table 4.2.1.1 Building Performance Factor (BPF)

|                              | Clima           | te Zone         | e    |      |      |      |      |      |      |      |      |      |      |      |      |      |      |
|------------------------------|-----------------|-----------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| <i>Building</i><br>Area Type | 0A<br>and<br>1A | 0B<br>and<br>1B | 2A   | 2B   | 3A   | 3B   | 3C   | 4A   | 4B   | 4C   | 5A   | 5B   | 5C   | 6A   | 6B   | 7    | 8    |
| Multifamily                  | 0.68            | 0.70            | 0.66 | 0.66 | 0.69 | 0.68 | 0.59 | 0.74 | 0.76 | 0.74 | 0.70 | 0.73 | 0.75 | 0.68 | 0.71 | 0.68 | 0.72 |
| Healthcare/<br>hospital      | 0.60            | 0.60            | 0.58 | 0.54 | 0.56 | 0.55 | 0.55 | 0.55 | 0.54 | 0.54 | 0.57 | 0.52 | 0.54 | 0.57 | 0.52 | 0.57 | 0.57 |
| Hotel/motel                  | 0.55            | 0.53            | 0.53 | 0.52 | 0.53 | 0.54 | 0.54 | 0.53 | 0.53 | 0.52 | 0.50 | 0.51 | 0.51 | 0.50 | 0.51 | 0.50 | 0.50 |
| Office                       | 0.52            | 0.57            | 0.50 | 0.56 | 0.53 | 0.56 | 0.48 | 0.51 | 0.52 | 0.49 | 0.51 | 0.51 | 0.49 | 0.52 | 0.51 | 0.49 | 0.51 |
| Restaurant                   | 0.63            | 0.64            | 0.60 | 0.60 | 0.60 | 0.61 | 0.58 | 0.62 | 0.57 | 0.61 | 0.63 | 0.60 | 0.64 | 0.65 | 0.62 | 0.67 | 0.70 |
| Retail                       | 0.51            | 0.54            | 0.49 | 0.55 | 0.51 | 0.55 | 0.53 | 0.51 | 0.55 | 0.54 | 0.50 | 0.54 | 0.55 | 0.50 | 0.51 | 0.48 | 0.50 |
| School                       | 0.39            | 0.47            | 0.38 | 0.43 | 0.38 | 0.42 | 0.40 | 0.37 | 0.40 | 0.38 | 0.36 | 0.40 | 0.36 | 0.36 | 0.37 | 0.36 | 0.37 |
| Warehouse                    | 0.38            | 0.42            | 0.40 | 0.42 | 0.43 | 0.44 | 0.43 | 0.44 | 0.43 | 0.46 | 0.49 | 0.47 | 0.48 | 0.54 | 0.51 | 0.57 | 0.57 |
| All others                   | 0.56            | 0.57            | 0.50 | 0.52 | 0.50 | 0.54 | 0.53 | 0.53 | 0.52 | 0.54 | 0.51 | 0.51 | 0.50 | 0.50 | 0.50 | 0.50 | 0.46 |

 $PCI_t = [BBUEC + (BPF \times BBREC)]/BBP$ 

#### where

- PCI = Performance Cost Index calculated in accordance with Section G1.2.
- BBUEC = baseline *building* unregulated *energy* cost, the portion of the annual *energy* cost of a *baseline building design* that is due to *unregulated energy use*.
- BBREC = baseline *building* regulated *energy* cost, the portion of the annual *energy* cost of a *baseline building design* that is due to *regulated energy use*.
- BPF = *building* performance factor from Table 4.2.1.1. For *building* area types not listed in Table 4.2.1.1 use "All others." Where a *building* has multiple *building* area types, the required BPF shall be equal to the area-weighted average of the *building* area types.

BBP = baseline building performance.



PNNL-25202 Rev. 1

**Developing Performance Cost Index Targets for ASHRAE Standard 90.1** Appendix G – Performance Rating Method March 2016 M Rosenberg R Hart ENERGY Prepared for the U.S. Department of Energy under Contract DE-AC05-76RL01830

https://www.pnnl.gov/main/pu blications/external/technical\_re ports/PNNL-25202Rev1.pdf

### C407, Welcome to ASHRAE 90.1



| Building                |      |            |      |
|-------------------------|------|------------|------|
| Area Type               | 4C   | 5 <b>A</b> | 5B   |
| Multifamily             | 0.74 | 0.70       | 0.73 |
| Healthcare/<br>hospital | 0.54 | 0.57       | 0.52 |
| Hotel/motel             | 0.52 | 0.50       | 0.51 |
| Office                  | 0.49 | 0.51       | 0.51 |
| Restaurant              | 0.61 | 0.63       | 0.60 |
| Retail                  | 0.54 | 0.50       | 0.54 |
| School                  | 0.38 | 0.36       | 0.40 |
| Warehouse               | 0.46 | 0.49       | 0.47 |
| All others              | 0.54 | 0.51       | 0.51 |

90.1-2019

| TABLE C407.3(2)                               |   |
|---|---|
| BUILDING PERFORMANCE FACTORS (BPF) TO BE USED | ) |
| FOR COMPLIANCE WITH SECTION C407.3            |   |

| Building Area Type  | Building Performance Factor |
|---------------------|-----------------------------|
| Multifamily         | 0.55                        |
| Healthcare/hospital | 0.71                        |
| Hotel/motel         | 0.53                        |
| Office              | 0.45                        |
| Restaurant          | 0.35                        |
| Retail              | 0.41                        |
| School              | 0.36                        |
| Warehouse           | 0.19                        |
| All Others          | 0.44                        |

TABLE C407.3(3) SITE ENERGY PERFORMANCE TARGETS TO BE USED FOR COMPLIANCE WITH SECTION C407.3

| Building Area Type  | Building Performance Factor |
|---------------------|-----------------------------|
| Multifamily         | 0.59                        |
| Healthcare/hospital | 0.72                        |
| Hotel/motel         | 0.62                        |
| Office              | 0.58                        |
| Restaurant          | 0.59                        |
| Retail              | 0.46                        |
| School              | 0.52                        |
| Warehouse           | 0.29                        |
| All Others          | 0.55                        |



 Table C407.3(2)

 Building Performance Factors (BPF) to be used for Compliance with Section C407.3

| Building Area Type   | Building Performance<br>Factor    |
|----------------------|-----------------------------------|
| Multifamily          | (( <del>0.51</del> )) <u>0.45</u> |
| Health care/hospital | 0.70                              |
| Hotel/motel          | (( <del>0.51</del> )) <u>0.46</u> |
| Office               | 0.44                              |
| Restaurant           | 0.33                              |
| Retail               | 0.41                              |
| School               | 0.35                              |
| Warehouse            | 0.18                              |
| All others           | 0.43                              |

### Table C407.3(3) Site Energy Performance Targets to be used for Compliance with Section C407.3

| Building Area Type   | Site Energy<br>Performance Targets |
|----------------------|------------------------------------|
| Multifamily          | (( <del>0.59</del> )) <u>0.53</u>  |
| Health care/hospital | 0.72                               |
| Hotel/motel          | (( <del>0.62</del> )) <u>0.56</u>  |
| Office               | 0.58                               |
| Restaurant           | 0.59                               |
| Retail               | 0.46                               |
| School               | 0.52                               |
| Warehouse            | 0.29                               |
| All others           | 0.55                               |



How hard is this (reprise)?

# Commissioning of HVAC required, plus...

- Cx qualifications, checklist
- Conflict of interest statement
- CX plan and Cx report
  - Lighting, controlled receptacles
  - HVAC, water heating
  - Refrigeration, Metering
- HVAC Cx thresholds:
  - 240 kBtu/h cooling
  - 300 Kbtu/h heating
- Write Cx requirement in mech permit docs, <u>including MEP sets</u>



**Take your project all the way across the finish line!** See C408.1.4.1.1 for Post-Occupancy Cx



Required (except very small systems)

**Certified Commissioning Professional** 

**CERTIFIED COMMISSIONING PROFESSIONAL.** An individual who is certified by an ANSI/ISO/IEC 17024:2012 accredited organization to lead, plan, coordinate, and manage commissioning teams and implement the commissioning process.

# Seattle: Approved unregulated loads C407.3.4.1

- You might get C407 "credit" for unregulated but high-performing systems
- If building official approves
- And it's a pretty high bar
- Will be publicly listed so everyone else can use as approved credit
- A few residential appliances preapproved
- Like maybe a "smart lab" fume hood ventilation control system?

### Metering Actionable energy display

- Graphic energy use display for bldgs. 20,000+ SF
  - Source meters (usually gas & elec pulse meters)
  - HVAC & water heating sub-meters
  - Lighting, plug load & process load sub-meters
- Also required for replacement HVAC systems
- Planning can reduce number of meters

Seattle City Light

nstruction & Inspections



### C409, The Cx Perspective

Meters, what are they good for anyway?



tsi

## Alterations C503


### **General principles:**

- Existing (untouched) can remain
- Service and repairs OK

**Seattle** Department of Construction & Inspections

- New equipment and new systems must meet code
- Seattle "Substantial Alterations" Whole *building* meets code
- Same with "change of occupancy," & "change of space conditioning"
- CBPS & BPS are a new departure

Seattle City Light



# Seattle: Replacement of existing gas equipment

- Most economical time to upgrade.
- Current (2018) Code. Replacement heating and water heating equipment must be heat pump system
  - <u>Exception</u> like-for-like replacement of "failing" equipment
- New (2021) Code. More options to postpone full conversion
  - But, no more option to "change nothing & keep burning gas forever"



# **BEPS:** Seattle


### Energy


- Most building types
- EUI targets set at state "average" for each building type
- Lower EUIs in future?
- 50,000 ft<sup>2</sup>: Starts 2026
- 20,000 ft<sup>2</sup>: Starts 2031


### **GHG Emissions**


- In addition to State BPS
- Emissions targets shrink every 5 years...
- ...to zero carbon in the 2040s
- 50,000 ft<sup>2</sup>: Starts 2028













## Future Decarbonization Plan Full engineered schematic design & cost estimate

- a. One-line system diagrams
- b. Equipment laid out to scale.
- c. Louvers, ducts, & air handling equipment
- d. Structural modifications
- e. Partitions & doors
- f. Electrical infrastructure
- g. Allowable roof coverage area & height
- h. Decarbonization planning form
- i. Schematic cost estimate
- j. Compliance dates for WA & Seattle Building Performance Standards



### Costs

### **Project Cost per Square Foot Comparison**



# Potential Cost Reductions

### **Problems**

- 1. Replacement heat pump system is big & expensive
- 2. Needs new electric service


### <u>Solutions</u>

- Do you really need that much heating capacity? Are existing systems oversized?
- 2. Is metered building electric use as high as the default code assumption?
  - Electrical code allows metered peak + 25%

### Image: Ecotope, Seattle 2023

#### **Comparing Design Predictions to Actual Peak Flow Rates**

Peak Hot Water Flow Rates in Multifamily Buildings



Many thanks to the Association for Energy Affordability, Ecotope, Frontier Energy, Peter Skinner, and the UC Davis Western Cooling Efficiency Center for providing data.


# BPS collision with code? Not really.

| Building Type          | 2018 SEC<br>EUI<br>(guess) | 12% lower<br>(2021 SEC<br>target) | Best local<br>examples | 2030<br>Target<br>EUI | WA BPS<br>target |
|------------------------|----------------------------|-----------------------------------|------------------------|-----------------------|------------------|
| High-rise office       | 38                         | 33                                | 37                     | 28                    | 63-69            |
| Mid-rise office        | 34                         | 30                                | <mark>16, 21</mark> (  | 22                    | 63-69            |
| Mid-rise multifamily   | 32                         | 28                                | 17, 19                 | 20                    |                  |
| Elementary school      | 28                         | 25                                | 16, 18 - 20            | 19                    | 49               |
| Warehouse, conditioned | 18                         | 16                                |                        | 12                    | 36               |



## BEPS & Code: Two paths, same destination

- <u>BEPS</u> sets date certain for decarbonization
- <u>Energy code</u> requires heat pump as systems are replaced
  - with options to postpone
- <u>Postpone</u>, or not, based upon:
  - Construction cost: <u>Pay me now</u>
  - Years until BPS or BEPS would mandate upgrade anyway: <u>Pay me later</u>





# Cooling system alterations C503.4.1

- When adding cooling to an "uncool" space, must provide either DOAS or economizer, both at the individual equipment level and the total system level
- Alteration or replacement of cooling system: <u>Table C503.4.3</u> Economizer options

|                   | Option A   | Option B<br>(alternate to A)   | Option C<br>(alternate to A)  | Option D<br>(alternate to A)  |
|-------------------|--|--|---|---|
| Unit Type         | Any alteration with new or replacement equipment                 | Replacement unit of the<br>same type with the same or<br>smaller output capacity   | Replacement unit of the<br>same type with a larger<br>output capacity   | New equipment added to<br>existing system or<br>replacement unit of a<br>different type |
| 1. Packaged Units | Efficiency: min. <sup>a</sup><br>Economizer: C403.5 <sup>b</sup> | Efficiency: min. <sup>a</sup><br>Economizer: C403.5 <sup>b</sup>   | Efficiency: min. <sup>a</sup><br>Economizer: C403.5 <sup>b</sup>  | Efficiency: min. <sup>a</sup><br>Economizer: C403.5 <sup>b</sup>                        |
| 2. Split Systems  | Efficiency: min. <sup>a</sup><br>Economizer: C403.5 <sup>b</sup> | For units ≤ 60,000 Btuh,<br>comply with two of two<br>measures:<br>1. Efficiency: + 10% <sup>e</sup><br>2. Economizer: shall not<br>decrease existing<br>economizer capability | For units ≤ 60,000 Btuh<br>replacing unit installed prior<br>to 1991 comply with at least<br>one of two measures:<br>1. Efficiency: + 10% <sup>e</sup><br>2. Economizer: 50% <sup>f</sup> | Efficiency: min. ª<br>Economizer: C403.5 <sup>b</sup>                                   |
|                   |  | For all other capacities:<br>Efficiency: min.ª<br>Economizer: C403.5 <sup>b</sup>  | For all other capacities:<br>Efficiency: min. <sup>a</sup><br>Economizer: C403.5 <sup>b</sup>   |   |

Economizer Compliance Options for Mechanical Alterations

### Seattle – Heat Pump Exception: Change in space conditioning – C505.2

# Where triggered by SEC 505.2, full energy upgrade of building not required under this exception:

1. A change in space conditioning does not require full compliance with this code if the existing heated but not cooled space is altered to become both heated and cooled solely by replacement of the existing heating-only HVAC system with an electric heat pump HVAC system, provided that there is no change in the use or occupancy classification of the area served by the HVAC system that would increase the cooling load, and the new system includes a DOAS with energy recovery in compliance with Section C403.3.5.



# Seattle: Air cooled chiller replacement C503.4.3.1

**C503.4.3.1 Addition of new or replacement of existing air-cooled chiller systems.** Where one or more air-cooled chillers are added or replaced, and the existing HVAC heating equipment is included in one of the categories listed below and is fossil fuel–fired or electric resistance, the replacement cooling appliance shall be an electric heat pump system in compliance with Section C403.1.4, integrated with the existing HVAC heating system and configured to serve as the first stage of heating when conditions permit use of the fluid temperatures produced by the heat pump system, with the existing fossil fuel–fired or electric resistance HVAC heating equipment serving as supplemental heat. Additions, alterations, or replacements shall not be made to an existing HVAC heating system that will cause the system to become out of compliance.

#### Exceptions:

Seattle City Light

Must replace aircooled chiller with heat pump system serving as first stage of heating.


- Exempt buildings
- Exempt system types

**Seattle** Department of Construction & Inspections

- . Exempt buildings and occupancies. The new heat pump is not required to serve as the first stage of heating if it serves any of the following building categories and the requirements of Section C503.4.6.2 are met.
  - <u>a.</u> <u>Affordable housing.</u>
  - b. Group I-1, I-2, and I-3 occupancies.
  - c. Buildings with more than 50 percent of conditioned floor area occupied by organizations recognized as nonprofit by the State of Washington or by federal tax law.
  - d. Buildings with no more than 20,000 square feet of conditioned floor area.
- 2. Exempt systems. Air-cooled chillers that serve dedicated server rooms, electronic equipment rooms, telecom switch rooms, or similar spaces that only require cooling and do not have any associated space heating equipment are not required to be replaced with heat pump systems. New heat pump systems are not required to serve as the first stage of heating if they serve any of the following system types, and if the requirements of Section C503.4.6.2 are met.
  - a. <u>Steam heating systems, including replacement of existing steam boilers with steam distribution</u> piping to terminal units and replacement of the existing associated boiler feed equipment.
  - b. Terminal unit equipment including but not limited to electric resistance VAV boxes, electric duct heaters, electric resistance fan coils, or electric resistance heaters.

### Adding cooling: a sticky situation





# <u>WA</u>: Replacement heating systems

### Replacement heating systems must comply with C403.1.4 (heat pump)

- Or an alternate compliance path from Table C503.4.6
- Or follow the FFCP, with all its extra credits

### **Exceptions:**

- Terminal units (VAV boxes, VRF units, fan coils, etc.)
- Air handlers with hydronic coils
- Air handlers with 100% outside air & not required to be DOAS
- Replacement of oil-fired & steam boilers
- Unplanned electrical service upgrade
- Replacement with same equipment type & capacity

# Seattle: Replacement heating systems

Replacement heating systems must comply with C403.1.4 (heat pump)

- Or an **alternate compliance path** from Table C503.4.6
  - Next slide

onstruction & Inspections

- And must also comply with C501.6 (Cx) & C506.1 (metering)
- Or follow "Fossil Fuel Compliance Path"
  - Including efficiency credits

Seattle City Light

### **Exceptions:**

- <u>Occupancies</u>: Affordable housing, institutional, non-profits, buildings <20,000 ft<sup>2</sup>
- Equipment:
- Terminal units (VAV boxes, VRF units, fan coils)
- Air handlers with hydronic coils
- Air handlers with 100% outside air & not required to be DOAS
- Replacement of oil-fired & steam boilers
- OK to maintain 50% of existing gas or resistance equipment capacity
- Temp replacement of 100% of existing
- Expensive utility upgrades

 Table C503.4.6

 Compliance Options for ((Mechanical))

 HVAC

 Heating Equipment Alterations


|   | Proposed Heating<br>Equipment Type <sup>a</sup>   | Heating Efficiency<br>Table Reference        | Alternate Compliance Options to Section C403.1.4   |
|---|---|--|--|
| 1 | Air-Cooled Unitary Heat<br>Pumps  | Table C403.3.2(2)                            | <ol> <li>Compliance with C403.1.4, except heat pump rated capacity in accordance with Section C403.1.4 exception 5d is permitted to be sized equal to the supplemental internal resistance heating capacity in Climate Zone 4 or 5<sup>c</sup></li> <li>Compliance with C403.1.4, except electric resistance mixed air preheat is permissible<sup>c</sup></li> </ol> |
| 2 | Packaged terminal, single-<br>package vertical, and room air-<br>conditioner heat pumps | Table C403.3.2(4)                            | 1. Compliance with C403.1.4, except heat pump rated capacity in accordance with Section C403.1.4 Exception 5d is permitted to be sized equal to the supplemental internal resistance heating capacity in Climate Zone 4 or 5   |
| 3 | Furnaces, duct furnaces, and<br>unit heaters  | Table C403.3.2(5)                            | <ul> <li><u>1. Permitted only when qualifying for and complying with Section</u></li> <li><u>C503.4.6 Exceptions 1, 2, 3 or 4</u></li> <li><u>2. Efficiency: ((+10%)) +5%</u><sup>b</sup></li> </ul>   |
| 4 | Gas-fired hot water boilers   | Table C403.3.2(6)                            | 1. Permitted only when qualifying for and complying with Section         C503.4.6 Exceptions 1, 2, 3 or 4         2. Efficiency: +5% <sup>b</sup>  |
| 5 | Variable refrigerant flow air-to-<br>air and applied heat pumps                         | Table C403.3.2(9)                            | No alternate compliance option   |
| 6 | DX-DOAS equipment   | Table C403.3.2(12) and<br>Table C403.3.2(13) | 1. DX-DOAS is provided with heat recovery if not required by C403.3.5.1.   |
| 7 | Water-source heat pumps   | Table C403.3.2(14)                           | No alternate compliance option   |

# Exceptions to C503.4.6

- 1. Exempt building types:
  - 1. Affordable housing
  - 2. Group I-1, I-2, I-3
  - 3. Nonprofits
  - 4. Smaller than 20,000 ft2
- 2. Retention of 50% of existing fuel type
- 3. Temporary replacement of failing equipment
  - 1. Temp Cof O
  - 2. Performance bond 2%
- 4. Utility service upgrade
  - 1. New or enlarged vault
  - 2. Trenching across vehicle lanes
  - 3. Exceeds 50% of project valuation

### Minimum Energy Performance for "Substantial Alterations" C503.9

- Once in a generation "deep green" retrofit
- For major alterations (like complete gut-and-remodel) <u>nearly</u> full compliance required
- "...substantially extends the useful physical or economic life of the building"
  - Or, vacant for more than 24 months
  - Or, major flood/fire damage repair
- "Impracticality" clause
- Also seismic & life safety



### Substantial Alterations: (Also) a sticky situation





### Industrial & Commercial Process loads? Typically not regulated, but *lots* of exceptions:

- Any specific code requirements
  - Like data center cooling
- C403 HVAC see these exceptions
- C404.2, SWH equipment efficiency
- C404.6, Pipe insulation
- C404.13, Service water pressure booster systems
- C405.8 Electric motor efficiency
- C410 Refrigeration systems
- C412 Compressed air systems

- **C403.3.2** HVAC equipment performance requirements furnaces, HVAC controls, chillers, package and split system equipment, humidification, hot gas bypass...
- Tables C403.3.2 (1) through (16) inclusive Equipment
- C403.3.4.1 Boiler combustion air positive shut-off
- **C403.3.4.2** Boiler system oxygen concentration controls (fan systems)
- **C403.3.4.3** Boiler oxygen concentration controls
- C403.7.7 Exhaust systems kitchen, lab, transfer air
- **C403.9.2.1** Condenser heat recovery for service water heating
- **C403.10.3** Piping for HVAC heating and cooling systems
- C403.11.2 Snow and ice melt systems
- **C403.11.3** Freeze protection (basically heat trace)

Health Comfort Environment Durability Quiet Beauty

There's more to life than energy efficiency

### Q & A and closing

### • Questions?

- Duane Jonlin, duane.jonlin@seattle.gov, 206-233-2781
- Ben Rousch, <u>benr@fsi-engineers.com</u>
- City Light Energy Advisors, <u>SCLEnergyAdvisor@seattle.gov</u>, 206-684-3800
- Lighting Design Lab, <u>lightingdesignlab@seattle.gov</u>
- Take the survey!

# **THANK YOU**



lightingdesignlab.com | 🖂 lightingdesignlab@seattle.gov